



NOTE: 4" FIRELINE CONNECTION WITH 1-1/2" UP TO 2" DOMESTIC SERVICE SHALL USE A 4" M.J. X 1 1/2" UP TO 2" THREADED TEE.



FIRELINE CONNECTION WITH DOMESTIC SERVICE TEE UP TO 3"



FIRELINE CONNECTION WITH DOMESTIC SERVICE TEE 4" AND LARGER

- (1) EXISTING MAIN
- (2) TAPPING SLEEVE
- (3) TAPPING VALVE
- (4) DOUBLE SPIGOT PIPE
- (5) PROPERTY LINE VALVE
- (6) MEGALUG
- (7) CONCRETE KICKBLOCK
- (8) DOMESTIC SERVICE TEE
- (9) POLYETHYLENE WRAPPED
- (10) 90° FITTING
- (11) VALVE AS REQUIRES ON P CONTINUE PER APPLICABLE METER DETAIL (SEE SHEETS 46-59)
- (12) PLUG TAPPED TO DOMESTIC SIZE. (UP TO 3")
- (13) CORP STOP (UP TO 3")
- (14) COPPER TUBING (UP TO 3")

DENVER WATER 1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851		
FIRELINE CONNECTION WITH DOMESTIC SERVICE TEE		
Scale: <u>NONE</u>	Date: <u>JULY 1995</u>	
Drawn: <u>C.B.B.</u>	Tr: <u> </u>	Ck: <u> </u>
Approved: <u> </u>		Dr. <u>127</u> No. <u>35</u>